


		ACTUATOR POSITION		
		CLOSED	MOVING	OPEN
CLOSED LIMIT SWITCHES	CLS and ACS 1-2		█	█
	CLS and ACS 1-3	█		
OPEN LIMIT SWITCHES	OLS and AOLS1-2	█	█	
	OLS and AOLS 1-3			█
TORQUE LIMIT SWITCHES	CTS 1-3	INTERRUPTS CONTROL IF MECH OVERLOAD OCCURS DURING CLOSED CYCLE		
	OTS 1-3	INTERRUPTS CONTROL IF MECH OVERLOAD OCCURS DURING OPEN CYCLE		

ACTUATOR SHOWN IN MID TRAVEL POSITION

----- CUSTOMER/FIELD WIRING

 <p>AVCS automated valve component & specialties</p>	TITLE	
	<p>AVE015 thru AVE250 ELECTRIC ACTUATOR 120 VOLT - ON/OFF</p>	
<p>AVCS.CO.COM PH 612-436-8350</p>	<p>BY JS-6/2017</p>	<p>DWG NO WD21202-1</p>